Grams: "Water Sup" Bangalore
Email: eic@bwssb.gov.in
Fax: 080 – 22945105
Phone:080 22945105

ಬೆಂಗಳೂರು ನೀರು ಸರಬರಾಜು ಮತ್ತು ಒಳಚರಂಡಿ ಮಂಡಳಿ

BANGALORE WATER SUPPLY AND SEWERAGE BOARD

O/o Engineer – In – Chief

II Floor, Cauvery Bhavan, K.G.Road, Bangalore-560009

No. BWSSB/EIC/ACE(CS & DCW)/TA/9960 /2025-26 **Dated: 27.03.2026**

ADDENDUM-1

Sub: Tender for the Work of Modernization & Re-modeling of Water Supply system in Frazer Town -5 under AEE(C-1-2) sub-division limits of BWSSSB, Bangalore- Points for pre-bid clarifications-Reg.

Ref: NIT No. BWSSB/EIC/ACE(CS & DCW)/TA/9741/2025-26 Dtd: 18.03.2026.

****

In continuation to the IFT vide above cited reference, the addendum with respect to queries raised is issued as follows:

<table>
<tr><th>Sl. No</th><th>Pre-bid queries</th><th>Response</th></tr>
<tr><td>1.</td><td>As per section -2 –(3) Qualification of Tenderer, under Clause 3.2.3(b), it is mentioned that,
Supply , laying jointing , testing commissioning of service connections making bore holes for fix house service connections including road cutting, excavation, backfilling, disposal and road restoration-4812 Nos. Whereas, as per Bill of Quantities, the HSC is only 1,205 Nos . Kindly clarify</td><td>Tender conditions prevail.</td></tr>
<tr><td>1.</td><td>As per Bill of Quantities, Item Code No. 14 and 15 , it is mentioned that, DI Pipe class mentioned as K-7, Please clarify that, the same is K-7 or K-9 class DI Pipes</td><td>To be read as K-9 class</td></tr>
<tr><td>2.</td><td>As per Bill of Quantities, Item code No. 32 and 33, the unit is mentioned as Sqm. Please clarify,</td><td>To be read as Cum</td></tr>
<tr><td>3.</td><td>As per section 6, in contract data- In payment terms for DI pipes as :-
<table>
<tr><td>As per tender documents</td><td>We request you to please consider as</td><td></td></tr>
<tr><td>60% of the contract price</td><td>70% of the contract price</td><td>After supply of DI pipes to site of work.</td></tr>
<tr><td>20% of the contract price</td><td>10% of the contract price</td><td>After laying of DI pipes.</td></tr>
<tr><td>10% of the contract price</td><td>10% of the contract price</td><td>After certification of Hydraulic testing of DI pipeline and commissioning of</td></tr>
</table></td><td>Tender conditions prevail.</td></tr>
</table>

			DI pipeline work including delinking of existing pipeline.	
	10% of the contract price	10% of the contract price	After Road Restoration	
4.	We request you to please clarify that, there is a Clause No. 39.1 wherein, it mentioned that "The rates quoted by the contractor shall be deemed to be inclusive of the sales and other taxes that the contractor will have to pay for the performance of this contract. The Employer will perform such duties in regard to the deduction of such taxes at source as per applicable law"			Tender conditions prevail.

All other conditions remain unaltered.

Engineer-In-Chief
BWSSB